

# FIRE SAFETY CERTIFICATE

## APPENDIX XII


NO: 136 /2025  
R.C.NO: 445 / V /2025

DATE: 15.05.2025

Certified that the **RANE VIDYALAYA- SETHURAPATTI** at S.F.NO.85/2A, 2B, 2C, 2D, 2E, 2F, 2G, 2H, 2I, 2J, 2K1, 2L1, 2M1 AND 2N AT 82, SETHURAPATTI VILLAGE, MANIKANDAM BLOCK, SRIRANGAM TALUK, TIRUCHIRAPPALLI- 620012, TAMILNADU Comprised of **MAIN BLOCK** Owned by **RANE VIDYALAYA- SETHURAPATTI** have complied with the fire prevention and the fire safety requirements in accordance with rule of state Fire Service, and verified by **P. SATHYAVARTHANAN, B.SC., B.L., ASSISTANT DISTRICT OFFICER**, on **15.05.2025** in the presence of **THE TRUSTEE- RANE FOUNDATION, RANE VIDYALAYA- SETHURAPATTI** And that the building is fits for occupancy up to classes **PRE-KG to VIII** With effect from **15.05.2025** for a period of **ONE YEAR** in accordance with rule and subject to compliance of specific conditions as appended:-

## CONDITIONS

- (i) SHOULD NOT EXCEED 1200 NO OF STUDENTS
- (ii) AS PER NATIONAL BUILDING CODE 2016 ALL PASSIVE MEASURES SHOULD BE FOLLOWED.
- (iii) NO CHANGES SHOULD BE MADE TO THE SETTINGS IN THE APPROVED PLAN.
- (vi) AS PER NATIONAL BUILDING CODE 2016 ALL FIRE FIGHTING EQUIPMENTS SHOULD BE INSTALLED AND MAINTAIN PROPERLY. SHOULD BE DESIGNATE A PERSON RESPONSIBLE FOR FIRE AND LIFE SAFETY. SHOULD BE CONDUCT BASIC FIRE FIGHTING AND EVACUATION DRILL AND FIRE MOCK DRILL ONCE IN THREE MONTHS.

  
Signature with Seal

Name: **P. SATHYAVARTHANAN, B.SC., B.L.,**

Designation: **ASSISTANT DISTRICT OFFICER,**

Name & Address of Department/Office: **TAMIL NADU FIRE AND RESCUE SERVICE,  
TIRUCHIRAPPALLI STATION.**



TO:

**THE TRUSTEE- RANE FOUNDATION,  
RANE VIDYALAYA- SETHURAPATTI,  
NO-82, SETHURAPATTI VILLAGE,  
MANIKANDAM BLOCK, SRIRANGAM,  
TIRUCHIRAPPALLI- 620012, TAMILNADU.**

**COPY TO: DISTRICT OFFICER, TAMIL NADU FIRE AND RESCUE SERVICE,  
TIRUCHIRAPPALLI DISTRICT.**